



TYPE B: LONG SIDE BEND TO TEE.

TYPE B MODIFIED: SHORT SIDE BEND TO TEE.

| MAIN LINE | DIMENSION L |             |
|-----------|-------------|-------------|
|           | TYPE B      | TYPE B MOD. |
| 6"        | 24"         | 19"         |
| 8"        | 25"         | 20"         |
| 12"       | 28"         | 23"         |
| 16"       | 31"         | 26"         |

NOTE:

FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.

E:\Construction\Standard Details\Del-Co\ID-3 Hydrant Setting Type B.dwg, 1. 12/9/2004 3:18:01 PM, PER



**Del-Co**  
**Water Co., Inc.**  
 6773 OLENTANGY RIVER RD.  
 DELAWARE, OH 43015

## HYDRANT SETTING TYPE B

REVISED  
 01 DEC 04

SCALE  
 NTS

PAGE 1 OF 1

D-3